

**CENTRAL ONTARIO ANALYTICAL LABORATORY INC.**



4260 Burnside Line, R.R. #4  
 Orillia, ON L3V 6H4  
 Tel: (705) 326-8285 Fax: (705) 326-9316  
[www.coalab.ca](http://www.coalab.ca)

**Final Certificate of Nitrate and Nitrite Analysis of Water**

Date & Time Received:	Temp. Rec'd. (°C):	Receiver:
2015-01-22 09:55	12.8	AB

Date Sampled:	2015-01-22	Twp/Town	Gravenhurst
Collected By:	Gerald Enchin	Systems Health Unit	SMDHU
Name of Facility	Camp Winston	Regulation	170/03
<b>Drinking Water System (DWS) #</b>	<b>Please See Below</b>	Total # of pages sent	1
		# of samples sent	1
		# of samples received	1

Report To: **Camp Winston ATTN: Gerald Enchin**  
 1147 River Lane R.R. #2 Kilworthy, ON P0E 1G0  
 Address: Mailing: Camp Winston c/o Pine Bay Foundation 55 Eglinton Avenue East, Suite 312, Toronto, ON M4P 1G8  
 Telephone: 705 689-9096 Ext: Fax: Scan & Email  
 Email Address: mail@campwinston.com; gerald@campwinston.com  
 "Live Person" After Hours Contact Name and Tel. No: Gerald Enchin cell: 416-453-4504

Submitted By: \_\_\_\_\_  
**Conditions/Comments**

Time Sampled	Sample Identifier	Identification of Collection Site	Water Type	Temp. Of Sample (°C/°F)	Treatment Information				Laboratory Number	Nitrate as N		Nitrite as N		Nitrate + Nitrite as N	
					U.V.	Other	Total Cl <sub>2</sub> (mg/L)	Free Cl <sub>2</sub> (mg/L)		>/<	mg/L	>/<	mg/L	>/<	mg/L
<b>Jean Lodge #260092690</b>															
08:58	1		E						SFA-030	0.036	<	0.010		0.036	
<b>New Building #260092716</b>															
09:12	2		E						SFA-031	<	0.010	<	0.010	<	0.010

**All samples will be considered DISTRIBUTION samples unless otherwise indicated. All times are transcribed in the 24-hour clock for upload to the Ministry of the Environment (MOE) and/or Ministry of Health and Long Term Care (MoHLTC).**

Analysis performed by qualified analysts. Results relate only to the aliquot submitted. Samples have been analyzed as received. COAL is accredited by SCC and licensed by MOE in these specific inorganic parameters. Raw = R  
 Distribution = D  
 Point of Entry = E  
 Raw Water Consumed = RWC

COAL accepts no responsibility for parameters selected, misidentification of samples or incorrect quantity, this is the responsibility of the submitting agency.

For collection and handling procedures visit [www.coalab.ca/watersamples.html](http://www.coalab.ca/watersamples.html)

N/R = Not Received      N/A = Not Applicable

Analysis Date & Time: 2015-01-22 14:30 Analyzed By: AF Audited By: JT Methodology: SFA mg/L  
 Transcribed By: AB Authorized & Rechecked By: KN/JT Copy Released By: JT/AB  
 Lab No: \_\_\_\_\_ Parameter: \_\_\_\_\_ Submitting Agency @ \_\_\_\_\_ H.U. @ \_\_\_\_\_ SAC @ \_\_\_\_\_ AWQI # \_\_\_\_\_ By: \_\_\_\_\_ Date: \_\_\_\_\_

Test Methodology (SFA) and Detection Lim									
Nitrate	COAL N	Detection Limit	0.010 mg/L	Reportable Limit:	10.0 mg/L	Methodology:	Automated Colourmetric Determination of Nitrate as N in water samples (modified EPA353.2)		
Nitrite	COAL N	Detection Limit	0.010 mg/L	Reportable Limit:	1.0 mg/L	Methodology:	Automated Colourmetric Determination of Nitrite as N in water samples (modified EPA353.2)		
Nitrate + Nitrite	COAL N	Detection Limit	0.010 mg/L	Reportable Limit:	10.0 mg/L	Methodology:	Automated Colourmetric Determination of Nitrate + Nitrite as N in water samples (modified EPA 353.2)		